



Product Service

CERTIFICATE

No. B 098200 0035 Rev. 02

Holder of Certificate: **Caledonian Cables Limited**
1/F., CMA Building, 64-66 Connaught Road Central,
Central and Western District
HONG KONG

Certification Mark:



Product: **Fire Resistant Cables**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 64105180658703

Valid until: 2029-12-16

Date, 2024-12-17

(Martin Ma)

CERTIFICATE

No. B 098200 0035 Rev. 02

Model(s): **FFX200 05SOZ1-U, FFX200 05SOZ1-R**

Parameters:

Rated voltage:	300/500V
Conductors:	Plain or tinned annealed copper wire, class 1(FFX200 05SOZ1-U), class 2(FFX200 05SOZ1-R)
Insulation:	Silicone rubber
Screen:	Aluminium/Polyester foil with circuit protective conductor (for 2, 3, 4 cores), or drain wire (for 7, 12, 19 cores)
Sheath:	Halogen free flame retardant compound
Size:	2 x 1.0 to 4.0 mm ² , 3, 4 x 1.5 to 4.0 mm ² , 7, 12 x 1.5 to 2.5 mm ² , 19 x 1.5 mm ² .
Fire resistance category:	BS 6387 CWZ EN 50200 PH120, EN 50200 Annex E

Tested according to: BS 7629-1:2015
BS 6387:2013
EN 50200:2015
IEC 60332-3-24:2018
IEC 60754-1:2011/AMD1:2019
IEC 60754-2:2011/AMD1:2019
IEC 61034-2:2005/AMD2:2019